

<p style="text-align: center;">18-03 ADDENDUM #2 NOVEMBER 24, 2017</p>

- 1) *Is there an estimated project value for this bid?*

The estimated project is \$80,000.

- 2) *Could you please advise us as to what material the roof on the upcoming project is composed of?*

The roofing material should be a Fabrene Q315WW, or equivalent.

- 3) *The alternate calls for grading and paving of the (existing salt shed) area after demolition. Does that include grading the steep sloped earth where the calcium chloride tank is located? If so, the tank will have to be moved. Alternatively, the lower half of the existing salt shed wall along the railroad bed (adjacent to the calcium chloride tank) could remain and act as a retaining wall.*

The calcium chloride tank will remain in place. You are also correct in assuming that the lower concrete portion of the salt shed that abuts the railroad bed will remain in place.