



**City of Salem, Massachusetts**  
 FIRE DEPARTMENT - FIRE PREVENTION BUREAU  
 29 Fort Avenue  
 Salem, Massachusetts 01970-5232

Fee Due ~~\$20.00~~ **\$30.00**  
 Ck. # \_\_\_\_\_  
 Rec'd by: \_\_\_\_\_

\_\_\_\_\_  
 (Date)

## APPLICATION FOR PERMIT

To: HEAD OF FIRE DEPARTMENT

In accordance with the provisions of the Mass. General Laws and/or the Salem Fire Code, application is hereby made for a permit to install approved fire alarm devices.

Location: \_\_\_\_\_ Owner: \_\_\_\_\_

Installer: \_\_\_\_\_ Tel # \_\_\_\_\_

Installer's Address: \_\_\_\_\_ Zip: \_\_\_\_\_ License # \_\_\_\_\_

Type of Occupancy: \_\_\_\_\_

- LIST TYPE AND LOCATIONS OF DEVICES ON REVERSE SIDE, OR PROVIDE PLANS. -

Installation subject to final inspection and filling of Certificate of Completion, by installer. Installer must be present.

Date of approval: \_\_\_\_\_ (Signature of Applicant)

Date of expiration: \_\_\_\_\_ (Address)

Form #81F (Rev. 04/92)

**DO NOT WRITE BELOW THIS LINE**



**City of Salem, Massachusetts**  
 FIRE DEPARTMENT - FIRE PREVENTION BUREAU  
 29 Fort Avenue  
 Salem, Massachusetts 01970-5232  
 (978) 745-7777  
 Office Hours: (8-9 A.M.) and (1-2 P.M.)

Fee Due ~~\$20.00~~ **\$30.00**  
 Ck. # \_\_\_\_\_  
 Rec'd by: \_\_\_\_\_  
 \_\_\_\_\_  
 (Date)

## PERMIT TO INSTALL - FIRE ALARM DEVICES

Permit is hereby granted to install approved fire alarm devices. All equipment and wiring are subject to approval of Salem Electrical Dept.

Location: \_\_\_\_\_ Owner: \_\_\_\_\_

Installer: \_\_\_\_\_ License # \_\_\_\_\_

Installer shall note special equipment required, as listed on reverse side. UPON COMPLETION, **THE INSTALLER SHALL REQUEST AN APPOINTMENT AT LEAST ONE WEEK PRIOR TO TEST, BE PRESENT FOR THE TEST, AND SIGN A CERTIFICATE OF COMPLETION.**

\_\_\_\_\_  
 (Signature of Fire Official)

\_\_\_\_\_  
 (Title)

Date of expiration: \_\_\_\_\_

**(THIS PERMIT MUST BE CONSPICUOUSLY POSTED UPON THE PREMISES)**

**NOTICE: ALL INSTALLERS ARE RESPONSIBLE FOR THE FOLLOWING:**

1. All equipment and devices shall be U.L. or F.M. type.
2. All zones (if required) shall be approved prior to installation of system. Zone plates shall be of a permanent type, and attached with non-returnable screws or rivets. If back lighted type, be sure to list approved zone completely.
3. The A.C. power shall be provided by use of a circuit breaker. Said circuit breaker shall be painted red, and provided with a screw lock.
4. A Sq. D 9001KS11K3 approved silence alarm key switch, with approved plate, shall be installed when any system has a fire alarm panel. Switch may be located on the fire alarm panel or the annunciator, as approved by the fire official.
5. An audible trouble buzzer shall be located in a common hallway or area open to the occupants. This audible buzzer shall be located on the exterior of any fire alarm panel or annunciator, to provide adequate audible volume.
6. Any deviation from approved plans or approved listing of devices, or approved location of said devices, shall require a request in writing, to the fire official. Request will be approved if the original intent and approval is not compromised.
7. Failure to request an appointment for testing of devices, shall be considered a violation of the fire code, and such action as deemed necessary shall be taken.
8. The installer shall have tested all equipment and devices, prior to test appointment time.
9. Adequate notice (one week) is required for appointments. Fire Emergencies may require a cancellation of any appointment.